



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

**Report Number:** 21-06-00618

**Received Date:** 06/04/2021  
**Reported Date:** 07/01/2021  
**Sampled By:** Sean Hanley  
**Tech Certification #:**

**Project/Test Address:** 2020L-120.1; Franklinville Jr/Sr High School; 31 North Main Street;  
Franklinville, NY 14737

**Client Number:**  
33-5980

**Fax Number:**  
716-312-8092

# Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-06-00618-001	120.1-6	05/26/2021	CONCESSION HAND WASH	14.6	06/29/2021	
21-06-00618-002	120.1-13	05/26/2021	ATHLETIC STORAGE SINK	35.2	06/29/2021	
21-06-00618-003	120.1-15	05/26/2021	BOYS LOCKER ROOM LEFT	2.19	06/29/2021	
21-06-00618-004	120.1-16	05/26/2021	BOYS LOCKER ROOM RIGHT	2.14	06/29/2021	
21-06-00618-005	120.1-19	05/26/2021	ROOM 008 RIGHT	182	06/30/2021	
21-06-00618-006	120.1-22	05/26/2021	ROOM 009 RIGHT	6.22	06/29/2021	
21-06-00618-007	120.1-28	05/26/2021	FRONT KITCHEN LINE HAND WASH	6.51	06/29/2021	
21-06-00618-008	120.1-32	05/26/2021	KITCHEN HAND WASH	23.8	06/29/2021	
21-06-00618-009	120.1-37	05/26/2021	KITCHEN DISH AREA HAND WASH	42.8	06/29/2021	
21-06-00618-010	120.1-50	05/26/2021	BASEMENT ART LEFT	6.51	06/29/2021	
21-06-00618-011	120.1-61	05/26/2021	GIRLS BATHROOM MIDDLE	7.90	06/29/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-06-00618

**Project/Test Address:** 2020L-120.1; Franklinville Jr/Sr High School; 31 North  
Main Street; Franklinville, NY 14737

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

**Method:** EPA 200.8

**Analyst:** Ailea Cabatbat

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

*Missy Kanode*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



STOHL Job # 2020L-120.1

Building: Franklinville Jr./Sr. High School      Location: 31 North Main Street Franklinville, NY 14737

## Turnaround

X

20 Days

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11

Ehenderson@StohlEnv.com

Archived / Released:                      QA/QC InterLAB Use:                      Date:                      Time: